

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-1574:131 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: ADT Security Services, Inc, 695 Route 46 West, Suite 200, Fairfield NJ 07004
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Model 1951 ADT ionization smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an ionization smoke detector for use with Notifer's listed Models BX501, B610LP, B612LP, B614LP or B710LP bases (CSFM Listing No 7300-0028:173) and separately listed compatible fire alarm control units. Suitable for open area protection at air velocities up to 1200 fpm.

XLf: 7271-0028:201

04-10-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 3, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager